

Sealant/Weatherproofing Division
Fire Protection Systems Group

GENERAL CERTIFICATE OF CONFORMANCE

DESCRIPTION: TREMCO® FIRE STOP PRODUCTS

<i>TREMstop Acrylic GG (Gun Grade)</i>	<i>TREMstop Acrylic SP (Spray)</i>
<i>TREMstop (IA) Intumescent Acrylic</i>	<i>TREMstop Silicone (Fyre-Sil)(Gun Grade)</i>
<i>TREMstop Silicone S.L. (Fyre-Sil S.L.)</i>	<i>Smoke and Sound Sealant (Tremflex 834)</i>
<i>TREMstop Anchors (Solid and Split)</i>	<i>TREMstop Composite Sheet</i>
<i>TREMstop Coupling</i>	<i>TREMstop Electrical Box Insert</i>
<i>TREMstop MP (Putty Pad)</i>	<i>TREMstop PSI & PS2</i>
<i>TREMstop Putty Stick</i>	<i>TREMstop WS</i>
<i>TREMstop D (Device)</i>	<i>TREMstop Fyre-Can / Fyre-Can TM</i>
<i>TREMstop Fyre-Can Sleeve</i>	<i>TREMstop MCR</i>
<i>TREMstop Strap</i>	<i>TREMstop UniCollar</i>
<i>TREMstop CIP Coupling</i>	<i>TREMstop CIP Pass Thru Copper</i>
<i>TREMstop CIP Water Closet</i>	<i>TREMstop CIP Pass Thru Cast Iron</i>
<i>TREMstop CIP Shower</i>	<i>TREMstop CIP Pass Thru Steel</i>
<i>TREMstop CIP Tub Box</i>	<i>TREMstop CIP Pass Thru EMT</i>
<i>TREMstop CIPP Plastic</i>	<i>TREMstop CIPP Metal</i>
<i>TREMstop Fire Mortar</i>	<i>TREMstop FS Blanket</i>
<i>DyMonic/DyMonic FC</i>	<i>Dymeric 240/Dymeric 240FC</i>
<i>Vulkem 45SSL</i>	<i>THC-900</i>

THESE PRODUCTS ARE TESTED TO ONE OR MORE OF THE FOLLOWING STANDARDS:

- ASTM E-119 (UL 263) Fire Tests of Building Construction and Materials Time-Temperature Curve
- ASTM E-814 (UL 1479) Fire Tests of Through-Penetration Fire Stops (under positive furnace pressure of minimum .01 inches of water column - 2.5+ Pascal)
- ASTM E-84 (UL 723) Surface Burning Characteristics of Building Materials
- UL 2079 Test for Fire Resistance of Building Joint Systems

No asbestos or PCB's are used or contained in these products.

Technical Services Manager

March 15, 2006

Date